

TOWN BOARD OF HEALTH
Town of Horicon
PO Box 90, Brant Lake, NY 12815
(518) 494-3647

NOTICE OF PUBLIC HEARING

Pursuant to Article V, Section E, of the Town of Horicon Sanitary Regulations, NOTICE IS HEREBY GIVEN, that the Horicon Town Board of Health will conduct a Public Hearing on Thursday, September 17, 2015 at 7:00 PM at the Horicon Community Center, 6604 State Rt. 8, Brant Lake, NY.

The Public Hearing is for a variance to install an alternative septic system at 1 Red Wing Rd, Adirondack, NY, Tax Map #20.10-1-13, which cannot meet the minimum setback requirements of Article III, Section D of the Horicon Sanitary Regulations. The owner, represented by Cedarwood Engineering, proposes to replace the current non-conforming septic system. The new alternative septic system will require variances for the following:

- 1-Septic tank to dwelling: 5ft (10ft required)
- 2-Septic tank to property line: 4.2 ft (10 ft required)
- 3-Distribution box to property line: 6.5 ft (10 ft required)
- 4-Distribution box to neighboring well: 96.4 ft (100 ft required)
- 5-Absorption field to property line: 1.1 ft (10 ft required)
- 6-Absorption field to dwelling: 2.5 ft (20 ft required)

All documents pertinent to said application may be viewed by contacting the Horicon Zoning Office at 6604 State Rt. 8, Brant Lake, NY during regular business hours.

By Order of the Horicon Town Board of Health
Krista Wood, Town Clerk